

All Water Year Types			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	60 cfs	215 cfs	<b>215 cfs</b>
December	100 cfs	401 cfs	<b>401 cfs</b>
January	100 cfs	579 cfs	<b>579 cfs</b>
February	100 cfs	538 cfs	<b>538 cfs</b>
March	100 cfs	456 cfs	<b>456 cfs</b>

\*Federal Energy Regulatory Commission has issued a new license to the Pacific Gas and Electric Company for the Potter Valley Hydroelectric Project, which asserts minimum instream flow requirement on the Eel River between Scott Dam to Cape Horn Dam as summarized in the above table. A compliance gage has not been identified for this stream section. Please contact the State Water Resources Control Board for further guidance.

**Web Link to FERC License:**

[FERC License #P-77 Potter Valley Hydroelectric Project](#)